

MINTO AND HUGHES CITY AC RFQ

ADDENDUM #1

MARCH 27, 2024

QUESTION #1, Should we assume we need to provide wind baffles on the AC unit to provide cooling
Operation down to -40 temperatures?

REPLY Yes

QUESTION #2, For both locations, do we know the approximate location of the main electrical panels
If they have space for a 2 pole breaker?

REPLY TCC has included with Addendum #1 relevant electrical drawings for both clinics.
Section #II of the RFQ requires each bidder to thoroughly examine the work area.