

Tanana Chiefs Conference Request for Proposals Battery Energy Storage System (BESS) & Independent Power Producer (IPP) Controller

Addendum Number Three (3)

October 10, 2025

The following corrections, changes, additions, deletions, revisions, and /or clarifications are hereby made as part of the request for proposals from the TCC Battery Energy Storage System (BESS) & Independent Power Producer (IPP) Controller.

Firms providing a proposal will acknowledge receipt of this addendum via email to Cortnie Doan at the following; cortnie.doan@tananachiefs.org

Final proposals to be emails to; cortnie.doan@tananachiefs.org

Updates to the following Deadlines

Registration/Question Deadline	September 19, 2025
Final Addendum Issued (Updated)	October 10, 2025
Deadline for Quote	October 24, 2025 (2:00 PM AKT)
Issue Notice of Intent to Award (NOITA)	October 31, 2025
Estimated execution of Construction Contract /Notice to Proceed	November 10, 2025
Construction Completion	September 30, 2026

AD3-1 Question: What is the intent of having the auxiliary panels/loads being fed from the medium voltage circuit? Is it acceptable to have these loads be fed from the inverter within the BESS system?


AD3-1 Reply: The goal is to provide a serviceable source of power to the BESS container independent of the BESS inverter. It can be acceptable to feed some or all auxiliary loads from the BESS inverter; if the contractor can confirm inverter's continuous/surge ratings, control/islanding behaviors, harmonics, protection, ground/isolation, warranty, etc.

AD3-2 Question: There are currently 480/480 Delta/Wye transformers shown at Huslia, Grayling and Minto. If the inverter we are proposing has a 4 wire/wye output, are these transformers still required? Or can these be deleted by our Engineer?

AD3-2 Reply: Alternative configurations that do not require a transformer will be acceptable and will be reviewed by the selection committee.

AD3-3 Question: We would like to request a bid deadline of 11/7.

AD3-3 Reply: No further extensions to the deadline.



AD3-4 Question: Can we trench and bury the comms?

If yes to the above question, can we assume we are also to move the PCC for the power to the outside of the power plant? If no to the above question, can we move the PCC for the Comms to the BESS?

AD3-4 Reply: Yes, Comms can be trenched and buried.

AD3-5 Question: Addendum 2 mentioned numerous times that the project specifics and responsibilities would be determined after award. Does TCC intend to negotiate final pricing with the selected contractor(s) after award depending on the outcome of the specifics?

AD3-5 Reply: Negotiations may happen depending on outcomes following the selections.

AD3-6 Question: Given that Addendum 3 is forthcoming, which is after the final questions will be expected, how does TCC expect contractors to address questions that result from Addendum 3's documents?

AD3-6 Reply: This is the final Addendum.
